



Technical Services, Inc.

88 Empire Drive • St. Paul, Minnesota • 55103  
(651) 642-1150 • fax (651) 642-1239

## **VOC Content Test Certificate**

February 19, 2024

Supplier: Hilti Entwicklungsgesellschaft mbH  
BU Chemicals  
Hiltistrasse 6  
86916 Kaufering  
GERMANY

Sample Description: Hilti All Weather High Build CFP-SP AWHB

Date Tested: February 14, 2024

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The testing also complies with the requirements of ASTM D2369-20.

Test Data:

Specification	Product
<b>LEED 4.1</b> Architectural paints, coatings and primers	<b>Hilti All Weather High Build CFP-SP AWHB</b>
<b>Green Building Council of Australia</b> Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
<b>Green Seal Standard GS-11</b> VOC Limit: 150 g/L	Product contains: 143 g/L of VOC

---

Tom Barrett  
Vice President/Strategic Analytical Services